

A PART CENTER RACEWAYS IN FOUNDATION RACEWAYS PARALLEL




TOP VIEW


NOTES



LIGHT POLE FOUNDATION DEPTH TABLE 40 FT. (12.192 m) TO 47.5 FT. (14.478 m) MOUNTING HEIGHT



TO EDGE OF PAVEMENT



TOP OF ANCHOR ROD

4" (100) MAX.

DESIGNED

CHECKED

DATE

EXOTHERMIC WELD CONNECTION TO REINFORCING STEEL 3½" X 36" RADIUS (88,9 Dig. X 914.4) PVC RACEWAY (2 MIN.) #2/0 BARE COPPER GROUND CLAMP UL LISTED 8-*6 VERTICAL BARS GROUND ROD (WHEN SPECIFIED)
5%" Dia. X 10'
(15,875 Dia. X 3,048 m) ----3 LOOPS MIN. AT TOP & BOTTOM ~ 2" (50,8) 3" (76,2)

*2/0 BARE COPPER

FOUNDATION DETAIL

24" (609.6) Dia.

GROUND LINE


REVISED


REVISED

REVISED

REVISED

04-22-02





SCALE: NONE

FOUNDATION EXTENSION DETAIL

- gagitanabt

PLOT SCALE - 56.0000 17 IN.

USER NAME

FB.L. NAME

f:\dimestd\22x34\ba30Ldgn

60" ((500)

SECTION A-A

STATE OF ILLINOIS **DEPARTMENT OF TRANSPORTATION**

LIGHT POLE FOUNDATION	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
(12.192 m) TO 47 1/2' (14.478 m) M.H. 15" (381 mm) BOLT CIRCLE	575	14-N	WILL	163	134
	BE-301		CONTRACT	NO. E	60前13
SHEET NO. 1 OF 1 SHEETS STA. TO STA.	FEO. R	DAD DIST. HO. I ILLINOIS FEO. A	O PROJECT	The section of the se	***************************************

BEFORE THE CONCRETE IN PLACED.

ALL DIMENSIONS ARE IN INCHES (MILLIMETERS) UNLESS OTHERWISE SHOWN.

THE ANCHOR RODS AND RACEWAYS SHALL BE PROPERLY SECURED IN PLACE

- THE FOUNDATION SHALL NOT PROTRUDE MORE THAN 100MM (4 IN.) ABOVE THE FINISHED GRADE WITHIN A 60 IN. (1.5 m) CHORD ACROSS THE FOUNDATION, WITH ANCHOR RODS INCLUDED, IN ACCORDANCE WITH AASHTO GUIDELINES. IF THE FOUNDATION HEIGHT, INCLUDING ANCHOR RODS. EXTENDS BEYOND THESE SPECIFIED LIMITS, THE FOUNDATION SHALL BE REPLACED AT THE CONTRACTOR'S EXPENSE, SEE FOUNDATION EXTENSION DETAIL.
- 4. THE HOLE FOR THE FOUNDATION SHALL BE MADE BY DRILLING WITH AN AUGER, OF THE SAME DIAMETER AS THE FOUNDATION, IF SOIL CONDITIONS REQUIRE THE USE OF A LINER TO FORM THE HOLE, THE LINER SHALL BE WITHDRAWN AS THE CONCRETE IS DEPOSITED.
- THE TOP OF THE FOUNDATION SHALL BE CONSTRUCTED LEVEL. A LINER OR FORM SHALL BE USED TO PRODUCE A UNIFORM SMOOTH SIDE TO THE TOP OF THE FOUNDATION, FOUNDATION TOP
- THE CONCRETE SHALL BE CLASS SI. CONCRETE SHALL CURE ACCORDING TO ARTICLE 1020.13 BEFORE LIGHT POLES ARE INSTALLED.
- 7. THE ANCHOR ROD SHALL BE A HOOK ROD TYPE, COLD BENDING OF THE ANCHOR ROD WILL NOT BE ALLOWED. THE RADIUS OF THE HOOK BEND SHALL NOT BE LESS THAN 4 TIMES THE NOMINAL DIAMETER OF THE ANCHOR ROD. A TACK WELDED ANCHOR ROD MAY BE SUBSTITUTED WITH THE APPROVAL OF THE ENGINEER.
- 8. THE ANCHOR RODS SHALL BE ACCORDING TO ASTM F1554 GRADE 725 (CRADE 105), NUTS SHALL BE HEXAGON NUTS ACCORDING TO ASTM A 194 2N OR ASTM A 563 DH, AND WASHERS SHALL BE
- 9. ANCHOR RODS, NUTS AND WASHERS SHALL BE COMPLETELY GALVANIZED BY EITHER THE HOT-DIPPED PROCESS COMFORMING WITH AASHTO M 232, THE MECHANICAL PLATING METHOD COMFORMING TO AASHTO M 298, CLASS 50 WITH A MAXIMUM COATING THICKNESS OF 150 UMG MILS) OR THE ELECTROLYTIC
- 10. THE ANCHOR RODS SHALL BE THREADED A MINIMUM OF 6 INCHES (150 mm) WITH A MINIMUM OF 3 INCHES (75 mm) OF THREADED ANCHOR ROD EMBEDDED IN THE FOUNDATION,
- 11. ANCHOR RODS SHALL PROJECT 274" (69.9 mm) ABOVE THE TOP OF THE FOUNDATION, IF BREAKAWAY COUPLINGS ARE SPECIFIED, THE CONTRACTOR SHALL CAREFULLY COORDINATE THE ANCHOR ROD PROJECTION WITH THE INSTALLATION REQUIREMENTS OF THE BREAKAWAY COUPLINGS.
- 12. THE CONTRACTOR SHALL USE A *3 SPIRAL AT 6" (152.4 mm) PITCH OR MAY SUBSTITUTE *3 TIES AT 12" (304.8 mm) O.C. WITH THE APPROVAL OF THE ENGINEER.

- 13. THE CABLE TRENCHES AND FOUNDATION SHALL BE BACK FILLED AND COMPACTED AS SPECIFIED BEFORE THE LIGHT POLE IS ERECTED.
- 14. THE RACEWAYS SHALL PROJECT I" (25.4 mm) ABOVE THE TOP OF THE FOUNDATION.